



To,  
DBMS College of Education  
Kadma, Jamshedpur  
Jharkhand-831005

WMD/LAB/TL-35/ 348 /26  
Date: 06.05.25

**Sub : Drinking Water Quality of your Institution**

Dear Sir/Madam

Water samples were received on **26.04.25** for analysis of the water quality at our laboratory. The water quality of the samples was found to be satisfactory. Chemical & Bacteriological analysis report is appended below.

**Chemical & Bacteriological analysis report.**

Sl. No.	Parameters	Source	Source	Standards / Norms	
		Incoming Water (Inlet)	Head Tank Outlet	World Health Organization (WHO)	Bureau of Indian Standards (BIS)
1	Turbidity (NTU)	0.8	1.0	$\leq 1.0$	$\leq 1.0$ (Acceptable) $\leq 5.0$ (Permissible)
2	pH	7.4	7.4	6.5-8.5	6.5-8.5
3	Free chlorine(mg/l)	0.5	0.2	$\geq 0.2$	$\geq 0.2$
4	Total Coliforms/100ml	Absent	Absent	Absent	Absent
5	E. coli/100ml	Absent	Absent	Absent	Absent

Thank you and we always assure you of our best services.

Yours Sincerely,

*Pragati Jha*

Asst. Manager/Dy. Manager  
Town Laboratory, Waterworks.  
Water & Wastewater Services.

*John Samirgita*  
Principal  
DBMS College of Education  
6-5-25

**TATA STEEL UTILITIES AND INFRASTRUCTURE SERVICES LIMITED**  
(Formerly Jamshedpur Utilities & Services Company Limited)

Registered Office Sakchi Boulevard Road Northern Town Bistupur Jamshedpur 831 001 India  
Tel 91 657 6652101 Fax 91 657 2424219  
Corporate Identity Number U45200JH2003PLC010315  
Website www.tatasteelluisl.com



*Monika*  
6/5/25  
**DR. MONIKA UPPA**  
IQAC CO-ORDINATOR  
D.B.M.S. COLLEGE OF EDUCATION