



To,  
DBMS College of Education  
Kadma

WMD/LAB/TL-35/1037-126  
Date: 17.02.2026

**Sub : Drinking Water Quality of your Institution**

Dear Sir/Madam


Water samples were received on 16/02/2026 for analysis of the water quality at our laboratory. The water quality of the OHT sample was found to be Satisfactory. Chemical & Bacteriological analysis report is appended below.

**Chemical & Bacteriological analysis report.**

Sl. No.	Parameters	Source	Source	Standards / Norms	
		Inlet water	OHT	World Health Organization (WHO)	Bureau of Indian Standards (BIS)
1	Turbidity (NTU)	0.90	1.0	≤ 1.0	≤1.0(Acceptable) ≤5.0 (Permissible)
2	pH	7.4	7.4	6.5-8.5	6.5-8.5
3	Free chlorine(mg/l)	0.2	0.2	≥ 0.2	≥0.2
4	Total Coliforms/100ml	Absent	<b>Absent</b>	Absent	Absent
5	E. coli/100ml	Absent	Absent	Absent	Absent

Thank you and always assure you our best services.

Yours Sincerely,

  
Manager/Dy. Manager  
Town Laboratory, Waterworks.  
Water & Wastewater Services.

**TATA STEEL UTILITIES AND INFRASTRUCTURE SERVICES LIMITED**

(Formerly Jamshedpur Utilities & Services Company Limited)

Registered Office Sakchi Boulevard Road Northern Town Bistupur Jamshedpur 831 001 India

Tel 91 657 6652101 Fax 91 657 2424219

Corporate Identity Number U45200JH2003PLC010315

Website www.tatasteeluisl.com